LGAI Technological Center, S.A. (APPLUS)
Campus UAB - Ronda de la Font del Carme s/n
08193 Bellaterra (Barcelona)
T +34 93 567 20 00
www.applus.com





Notified Body No. 0370

CERTIFICATE



No.

0370-CPR-3947

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

- PEDESTRIAN DOORSETS, INDUSTRIAL, COMMERCIAL, GARAGE DOORS AND OPENABLE WINDOWS. PRODUCT STANDARD, PERFORMANCE CHARACTERISTICS. FIRE RESISTING AND/OR SMOKE CONTROL CHARACTERISTICS
- INDUSTRIAL, COMMERCIAL, GARAGE DOORS AND GATES. PRODUCT STANDARD, PERFORMANCE CHARACTERISTICS

PRODUCT: CRFT MEC 120 MODELO VICTORIA

Place on the market under the name of:

NGR TECHNOLOGIE Sp. z o.o.

UL. ZIELONOGÓRSKA 8 62-065 GRODZISK WLKP.-POLAND

And produced in the manufacturing plant:

UL. ZIELONOGÓRSKA 8 62-065 GRODZISK WLKP.-POLAND

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 16034:2014, EN 13241:2003+A2:2016

under system 1 are applied and that the productfulfils all the prescribed requirements set out above.

This certificate was first issued on 6th March 2020 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

The monitoring assessment will be done before March 2021

Bellaterra, 6th March 2020

LGAI Technological Center, S.A.

Xavier Ruiz Peña

Managing Director, Product Conformity B.U.

This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate into our website at: https://apps.applus.com/microsites/microsites/FECIP/login

LGAI Technological Center, S.A. (APPLUS) Campus UAB s/n – Ronda de la Font del Carme, s/n E - 08193 Bellaterra (Barcelona)

T +34 93 567 20 00 www.appluslaboratories.com



06/03/2020

0370-CPR-3947

CERTIFIED PERFORMANCE

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Resistance to fire (for fire compartmentation uses)	4.1	EI ₂ 120
Smoke control (only for applications where limitation of smoke spread is required)	4.2	NA
Ability to release	4.3	Release
Self-closing (only for self-closing fire resistant and/or smoke control doorsets and /or openable windows)	4.4	С
Durability of ability to release	4.5.1	Release
Durability of self-closing (only for self- closing fire resistant and/or smoke control doorsets and/or openable windows)	4.5.2.1	0
- against degradation (cycling testing) - against ageing (corrosion)	4.5.2.2	NA

PASS; NPD = No Performance Determined; NA = Not Applicable