



DECLARATION OF PERFORMANCE

AKE120

Manufacturer: NGR TECHNOLOGIE Sp. z o.o.
Ul. Zielonogórska 8, 62-065 Grodzisk Wielkopolski, Poland

Product: ELASTIC FIRE-PROOFING ROLLED GATE AKE120

Product standard EN 13241:2003+A2:2016

Fire resistance 120 minutes integrity and 20 minutes radiation
performance to EN 16034:2014

Classification: E 120/EW20 to EN 13501-2

Certification number: 1812-CPR-1578

Certification Body: N° 1812, EFECTIS France, Saint-Aubin, France

Date and place of issuing
Grodzisk Wielkopolski, 24.04.2020

Signature valid in law

PREZES ZARZADU
"NGR TECHNOLOGIE" Sp. z o.o.

Damian Wartecki

"NGR TECHNOLOGIE" Sp. z o.o.
ul. Zielonogórska 8
62-065 Grodzisk Wilko.
Tel. 61 44 45 165, fax 61 44 45 172
NIP 529-172-04-56, Regon 140567617
KRS 0000256477