



Reg. No. 041/P-007

NOTIFIED BODY No. 1396  
Osloboditeľov 282, 059 35 Batizovce, Slovakia  
tel. +421 52 7752298 fax. +421 52 7881412 <http://www.fires.sk>



## Certificate of constancy of performance

**1396-CPR-0125**

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

### **ASB Automatic Smoke Barrier DH 120**

Active smoke barrier type ASB1 and ASB3, is designed as a part of smoke and heat control systems, for creation of smoke reservoirs inside the building, for control of movement of smoke and heat inside the building and for increase of efficiency of natural or powered smoke and heat exhaust ventilators

placed on the market under the name or trade mark of

**EF Polska Sp. z o.o., ul. Erazma Ciołka 17/420,  
01-445 Warsaw, Poland**

and produced in the manufacturing plant

**EF Polska Sp. z o.o., ul. Zielonogórska 8, 62-065, Grodzisk  
Wielkopolski, Poland**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 12101-1: 2005, EN 12101-1/A1: 2006**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on 12. 06. 2017 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

in Batizovce on 12. 06. 2017



*Ing. Mária Gašperová*  
Ing. Mária Gašperová  
Head of Product Certification Body

074045

FIRES 136a/C-31/01/2017-E